राध्द्रीय ताप विश्वत निगम और राज्य बोडी द्वारा टेरिफ-निर्धारण

- 4357. श्री सुम्बर सिंह भंडारी: क्या विद्युत मन्नी यह बताने की कृपा करेंगे
- है कि: राज्य (क) क्या यह सर्च बिजली बोड़ी को टैरिफ-निर्धारण के मामले में राष्ट्रीय तापविद्युत निगम के साथ चर्चा करने से वंचित कर दिया गया है : र्श्वोर
- (ख) क्या राष्ट्रीय ताप विद्यत निगम (एनटोपीसी)राष्ट्रीय जल विद्युत निगम (एन० एच०पी०सी०) की विद्युत परियोजनाओं के टैरिफ-निर्धारण को भी राष्ट्रीय तथा क्षेत्रीय परिषदों के कार्य-क्षेत्र के ग्रधीन जायेगा ?

विद्यात मंत्रालय के राज्य मंत्री श्री ः (क) केन्द्रीय विद्युत कल्पनाय राय) प्राधिकरण द्वारा एन०टी०पी०सी० के विद्युत उत्पादन केन्द्रों से बिद्युत की सप्लाई हेत् टैरिफ के सम्बन्ध में ब्रितिम निर्णय लिए जाने/इसे निर्धारित किए जाने से पहले एनटीपीसी स्रोर लाभभोगी राज्य बिजली बोडों के साथ विधार-विभर्ग किया जाता

(ख) केन्द्रीय विद्युत उत्पादन केन्द्रों से हेतु टैरिफ सम्बन्धी विद्युत की सप्लाई टैरिफ बोर्डो के भी विद्यत भ्र**बिकार क्षेत्र** में श्रा जायेगा ।

Setting up of gas based power project by NTPC in Faridabad

- 4358. SHRI S. S. SURJEWALA: Will the Minister of POWER pleased to state;
- (a) whether there is any proposal before the N.T.P.C. for setting up of a 840 M.W. gas based power project at Faridabad;
- (b) is so, whether the gas has been allocated by the Ministry of Petroleum and Natural Gas for the proposed plant;

- (c) what stages have been completed for the sanction of the project, so far;
- (d) when will its construction, starl and from where the finances are proposed to be arranged; and
- (e) how much share of power Haryana State will get from the proposed Faridabad gas based power project?

THE MINISTER OF STATE OF THE **MINISTRY** OF **POWER** (SHRI **KALP** NATH RAI): (a) to (d) A proposal has been received from the National Thermal Power Corporation (NTPC) for setting up a gas based combined cycle power project (800 MW) in Faridabad district of Haryana. The requirement of gas for a 800 MW base load project is 3 Million Cubic Meter Per Day (MCMD). The gas linkage available for this project is for 2 MCMD only. With the limited availability of gas of 2 MCMD, NTPC now proposes to set up only a 400 MW project at Faridabad. This would require revised techno-economic clearance by the Central Electricity Authority.

(e) The share of power to Haryana from Faridabad gas power project will be decided on the basis of the formula for allocation of power from Central Sector Projects.

Setting up of Thermal Power Project at Yamuna Nagar

- 4359. SHRI S. S. SURJEWALA: Will the Minister of POWER be pleased to state;
- (a) whether it is a fact that the NTPC propose to construct a 840 MW thermal power plant at Yamuna Nagar:
- (b) if so, in which year the NTPC undertook to construct the project and what progress has been made thereafter:
- (c) whether it is also a fact that all clearance including that of CEA, Planning Commission, Ministries