राष्ट्रीय ताप विद्युत निगम श्रीर राज्य विजली बोडों द्वारा टेरिफ-निर्धारण

Written Answers

- 4357. श्री सुन्दर सिंह मंडारी: क्या विजुत मन्नी यह बताने की कृपा करेंगे कि :
- (क) क्या यह सच है कि राज्य बिजली बोर्डों को टैरिफ-निर्धारण के मामले में राष्ट्रीय ताप विद्युत निगम के साथ चर्चा करने से बंचित कर दिया गया है ;
- (ख) क्या राष्ट्रीय ताप विद्युत निगम (एनटीपीसी)राष्ट्रीय जल विद्युत निगम (एन० एच०पी०सी०) की विद्युत परियोजनाओं के टैरिफ-निर्धारण को भी राष्ट्रीय तथा क्षेत्रीय परिषदों के कार्य-क्षेत्र के ग्रधीन रखा जायेगा ?

विद्युत मंत्रालय के राज्य मंत्री श्री कल्पनाथ राय) : (क) केन्द्रीय विद्युत प्राधिकरण द्वारा एन०टी०पी०सी० के विद्युत उत्पादन केन्द्रों से विद्युत की सप्लाई हेतु टैरिफ के सम्बन्ध में ग्रंतिम निर्णय लिए जाने/इसे निर्धारित किए जाने से पहले एनटीपीसी ग्रीर लाभभोगी राज्य बिजली बीडों के साथ विचार-विमर्ण किया जाता

(ख) केन्द्रीय विद्युत उत्पादन केन्द्रों से विद्युत की सप्लाई हेतु टैरिफ सम्बन्धी मामला भी विद्युत टैरिफ बोर्डों के ग्रविकार क्षेत्र में ग्रा जायेगा ।

Setting up of gas based power project by NTPC in Faridabad

4358. SHRI S. S. SURJEWALA: Will the Minister of POWER be pleased to state:

- (a) whether there is any proposal before the N.T.P.C. for setting up of a 840 M.W. gas based power project at Faridabad;
- (b) if so, whether the gas has been allocated by the Ministry of Petroleum and Natural Gas for the proposed plant;

- (c) what stages have been completed for the sanction of the project, so far;
- (d) when will its construction start and from where the finances are proposed to be arranged; and
- (e) how much share of power Haryana State will get from the proposed Faridabad gas based power project?

THE MINISTER OF STATE OF THE MINISTRY OF POWER (SHRI KALP NATH RAI): (a) to (d) A proposal has been received from the National Thermal Power Corporation (NTPC) for setting up a gas based combined cycle power project (800 MW) in Faridabad district of Haryana. The requirement of gas for a 800 MW base load project is 3 Million Cubic Meter Per Day (MCMD). The gas linkage available for this project is for 2 MCMD only. With the limited availability of of 2 MCMD, NTPC now proposes to set up only a 400 MW project Faridabad. This would require revised techno-economic clearance the Central Electricity Authority.

(e) The share of power to Haryana from Faridabad gas power project will be decided on the basis of the formula for allocation of power from Central Sector Projects.

Setting up of Thermal Power Project at Yamuna Nagar

4359. SHRI S. S. SURJEWALA: Will the Minister of POWER be pleased to state:

- (a) whether it is a fact that the NTPC propose to construct a 840 MW thermal power plant at Yamuna Nagar;
- (b) if so, in which year the NTPC undertook to construct the project and what progress has been made thereafter;
- (c) whether it is also a fact that all clearance including that of CEA, Planning Commission, Ministries of